

IEC**IECEE
CB
SCHEME**

Ref. Certif. No.

CN38447

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME****SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC****CB TEST CERTIFICATE**Product
Produit

Fuse-links for the protection of semiconductor devices

Name and address of the applicant
Nom et adresse du demandeurZhejiang Tengen Electrics Co.,Ltd.
TENGEN Industry Zone, Liushi Town, Yueqing City, Zhejiang
Province, P.R.ChinaName and address of the manufacturer
Nom et adresse du fabricantZhejiang Tengen Electrics Co.,Ltd.
TENGEN Industry Zone, Liushi Town, Yueqing City, Zhejiang
Province, P.R.ChinaName and address of the factory
Nome et adresse de l'usineZhejiang Tengen Electrics Co.,Ltd.
TENGEN Industry Zone, Liushi Town, Yueqing City, Zhejiang
Province, P.R.ChinaNote: When more than one factory, please report on page 2
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2^{ème} pageRatings and principal characteristics
Valeurs nominales et caractéristiques principalesUn: DC80V;In:
10A,16A,20A,25A,32A,40A,50A,63A,80A,100A,125A,
160A,200A,250A,300A,315A,350A,400A,500A,600A;Rated
breaking capacityI1: 25kA;Breaking range and utilization
category: gS
TENGENTrademark (if any)
Marque de fabrique (si elle existe)

NHZ1-00, NHZ1-00S

Model / Type Ref.
Ref. De typeAdditional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{ème} page)**PUBLICATION****EDITION**A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à laIEC 60269-4 (Fifth Edition) + A1:2012 see also IEC 60269-
1:2006 (Fourth edition) + A1:2009As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

03601-A-16CB0076-S-A,03601-A-16CB0076-S-B

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification****CHINA QUALITY CERTIFICATION CENTRE**

Date: 2016-09-26

Signature:

Wang Kejiao

Issued 2003-05
China Quality Certification Centre
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.ChinaTel: +86-10-83886666
Fax: +86-10-83886282website
www.cqc.com.cn**CB 0037352**