



Test Report issued under the responsibility of:



TEST REPORT
IEC/EN 60898-1
Circuit-breakers for over current protection for household and similar installations

Report Reference No.: 03601-A-17D0052-S
Date of issue: 2017-08-05
Total number of pages: 11

CB/CCA Testing Laboratory: Suzhou Electrical Apparatus Science Research Institute Co., Ltd.(EETI)
Address: No.7 Yonghe Street, Binhe Road, New District, Suzhou,China

Applicant's name: Zhejiang Tengen Electrics Co.,Ltd.
Address: Sulv Industrial Area, Liushi Town, Yueqing City

Test specification:

Standard: [X] EN 60 898-1:2003 + A1:2004 + A11:2006
Test procedure: CCA
Non-standard test method: N/A

Test Report Form No.: IECEN 60898_1C
Test Report Form(s) Originator: OVE
Master TRF: Dated 2007-03

Copyright © 2007 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

If this Test Report Form is used by non-CCA members, the CIG logo and the reference to the CCA Procedure shall be removed.

This report is not valid as a CCA Test Report unless signed by an approved CCA Testing Laboratory and appended to a CCA Test Certificate issued by an NCB in accordance with CCA

Test item description: Miniature circuit-breaker

Trade Mark: TENGEN

Manufacturer: Zhejiang Tengen Electrics Co.,Ltd.

Model/Type reference: TGB2-63

Ratings: Ue: AC230/400V(1P) , AC400V (2P, 3P,4P);
In: 1A,2A,3A,4A,5A,6A,10A,16A,20A,25A,32A,40A,50A,63A;
Type C ,Type D; Ics=Icn: 6kA;
1P, 2P,3P,4P

| Testing procedure and testing location: | |
|---|--|
| <input checked="" type="checkbox"/> CB/CCA Testing Laboratory: | Suzhou Electrical Apparatus Science Research Institute Co., Ltd.(EETI) |
| Testing location/ address.....: | No.7 Yonghe Street, Binhe Road, New District, Suzhou, China |
| <input type="checkbox"/> Associated CB Laboratory: | N/A |
| Testing location/ address.....: | N/A |
| Tested by (name + signature).....: | Dai Weiqiang |
| Approved by (+ signature) | Zhang Jie |
| <input type="checkbox"/> Testing procedure: TMP | N/A |
| Tested by (name + signature).....: | N/A |
| Approved by (+ signature) | N/A |
| Testing location/ address.....: | N/A |
| <input type="checkbox"/> Testing procedure: WMT | N/A |
| Tested by (name + signature).....: | N/A |
| Witnessed by (+ signature).....: | N/A |
| Approved by (+ signature) | N/A |
| Testing location/ address.....: | N/A |
| <input type="checkbox"/> Testing procedure: SMT | N/A |
| Tested by (name + signature).....: | N/A |
| Approved by (+ signature) | N/A |
| Supervised by (+ signature).....: | N/A |
| Testing location/ address.....: | N/A |
| <input type="checkbox"/> Testing procedure: RMT | N/A |
| Tested by (name + signature).....: | N/A |
| Approved by (+ signature) | N/A |
| Supervised by (+ signature).....: | N/A |
| Testing location/ address.....: | N/A |



Handwritten signatures in black ink: Dai Weiqiang and Zhang Jie.

| Summary of testing: | |
|--|--|
| Tests performed (name of test and test clause): N/A | Testing location: Suzhou Electrical Apparatus Science Research Institute Co., Ltd.(EETI) No.7 Yonghe Street, Binhe Road, New District, Suzhou,China |
| Summary of compliance with National Differences: N/A | |