



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE160303005175-A1

Product

Moulded Case Circuit-breakers

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGB3Z-63, TGB3Z-63H

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
00901-CE2016CQC0303-008209-A1, the submitted sample(s) of the above item complies
with:

EN 60947-2:2006 + A1:2009 + A2:2013

and fulfills testing requirements of the European Directive:

Low Voltage Directive(LVD): 2014/35/EU

Valid from: Oct.28,2019

Valid until: Oct.28,2022

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE

CERTIFICATE OF CONFORMITY

Appendix:

Page 1 of 1

No. : CE160303005175-A1

TGB3Z-63, TGB3Z-63H

Uimp:6kV

Ui:1000V

Ue:AC230V(1P),AC400V(2P,3P,4P),

DC80V(1P appearance),DC125V(2P appearance)

In:1A, 2A, 3A, 4A, 5A, 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A

Over-current release: thermal-magnetic

Ics: 6kA(TGB3Z-63,AC/DC), 7.5kA(TGB3Z-63H,AC),

10kA(TGB3Z-63H,DC)

Icu: 6kA(TGB3Z-63,AC/DC), 10kA(TGB3Z-63H,AC/DC)

Selectivity category:A

50/60Hz

1P,2P,3P,4P

IP20

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>