



产品认证证书

证书编号: CQC2011010302501116

申请人名称及地址

浙江天正电气股份有限公司
浙江省乐清市柳市镇苏吕工业区

制造商名称及地址

浙江天正电气股份有限公司
浙江省乐清市柳市镇苏吕工业区

生产企业名称及地址

浙江金莱勒电气有限公司 (V030325)
浙江省乐清市乐清经济开发区纬十路 246 号

产品名称和系列、规格、型号

负荷隔离开关

GL□-□/□□□□□□、GLS□-□/□□□□□□; Uimp: 12kV; Ui: 1000V; Ith: 1600A; Ue: AC380/400V;
Ie: 800A、1000A、1250A、1600A; 使用类别: AC-21B; Icw: 30kA/1s; Icm (峰值): 63kA;
极数: 3P、4P; 配用的辅助触头: Ith: 0.8A; 1NO1NC; 2NO2NC; AC-15: Ue/Ie: 220V/0.8A

产品标准和技术要求

GB/T 14048.3-2017

认证模式

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 11 月 02 日 有效期至: 2024 年 03 月 18 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2020 年 10 月 10 日

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0421089



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2011010302501116

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Zhejiang GRL Electric Co.,Ltd. (V030325)
No.246 Wei 10th Road, Yueqing Economic Development Zone, Yueqing, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Switch-disconnector

GL□-□/□□□□□□, GLS□-□/□□□□□□; Uimp: 12kV; Ui: 1000V; Ith: 1600A; Ue: AC380/400V; Ie: 800A, 1000A, 1250A, 1600A; AC-21B; Icw: 30kA/1s; Icm (peak): 63kA; 3P, 4P; Auxiliary contacts: Ith: 0.8A; 1NO1NC; 2NO2NC; AC-15; Ue/Ie: 220V/0.8A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.3-2017

TYPE OF CERTIFICATION SCHEMES

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

Valid from: Nov.02,2020

Valid until: Mar.18,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Oct.10,2020

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0421089



产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC2011010302501116

纸 号: 421089

型号的解释:

\square \square - \square / \square \square \square \square \square
(1) (2) (3) (4) (5) (6) (7) (8)

- (1) “GL” 表示负荷隔离开关, “GLS” 表示负荷隔离开关
- (2) 操作方式: “C” 表示侧方正面操作, “Z” 表示上下两个负荷开关转换操作, “Z2” 表示左右转换操作, 不需要时不注
- (3) 额定电流 (A): 800、1000、1250、1600
- (4) 极数: 3-3P, 4-4P
- (5) “J” 表示柜外操作, 柜内操作不注
- (6) “H” 表示柜后操作, 不需要时不注
- (7) “K” 表示带可视窗口, 不需要时不注
- (8) 辅助触点功能代号: “11” 表示一常开一常闭, “22” 表示二常开二常闭

注: 此附录与证书同时使用时有效。

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>