



# 产品认证证书

证书编号: CQC2016010302870669

## 申请人名称及地址

浙江天正电气股份有限公司  
浙江省乐清市柳市镇苏吕工业区

## 制造商名称及地址

浙江天正电气股份有限公司  
浙江省乐清市柳市镇苏吕工业区

## 生产企业名称及地址

浙江天正电气股份有限公司 (V024163)  
浙江省乐清市柳市镇柳乐路 332 号

## 产品名称和系列、规格、型号

刀型触头熔断器支持件

NHZ1-00; 额定电压 Un: AC690V/DC80V(160A), DC80V(250A, 600A); 额定电流  
In: 160A, 250A, 600A; 额定分断能力 I1: 50kA(AC690V), 25kA(DC80V); 极数: 1P

## 产品标准和技术要求

GB/T 13539.2-2015

## 认证模式

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 08 月 24 日 有效期至: 2021 年 05 月 30 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: \_\_\_\_\_

陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0374350



# PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2016010302870669

## NAME AND ADDRESS OF THE APPLICANT

Zhejiang Tengen Electrics Co.,Ltd.  
Sulv Industry Zone, Liushi, Yueqing, Zhejiang Province, P.R.China

## NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Tengen Electrics Co.,Ltd.  
Sulv Industry Zone, Liushi, Yueqing, Zhejiang Province, P.R.China

## NAME AND ADDRESS OF THE FACTORY

Zhejiang Tengen Electrics Co.,Ltd. (V024163)  
No.332 Liule Road, LiuShi Town, Yueqing City, Zhejiang Province

## PRODUCT NAME, MODEL AND SPECIFICATION

Fuse-Links holder with Blade Contacts  
NHZ1-00; Un:AC690V/DC80V(160A),DC80V(250A,600A);In:160A,250A,600A;Rated breaking capacity(I1):50kA(AC690V),25kA(DC80V);Poles:1P

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.2-2015

## TYPE OF CERTIFICATION SCHEMES

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

Valid from: Aug.24,2020

Valid until: May.30,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President:

Lu Mei



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0374350