



# 产品认证证书

证书编号: CQC2013010305590729

申请人名称及地址

浙江天正电气股份有限公司  
浙江省乐清市柳市镇苏吕工业区

制造商名称及地址

浙江天正电气股份有限公司  
浙江省乐清市柳市镇苏吕工业区

生产企业名称及地址

浙江天正电气股份有限公司 (V024163)  
浙江省乐清市柳市镇柳乐路 332 号

产品名称和系列、规格、型号

万能转换开关

LW28-20; Ui:550V; Uimp:2.5kV; Ith:20A; AC-15:Ue/le:AC380V/1.5A; DC-13:Ue/le:DC220V/0.14A.  
型号解释详见附件

产品标准和技术要求

GB/T14048.5-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 08 月 24 日 有效期至: 2022 年 11 月 28 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: \_\_\_\_\_

陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0376520



# PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2013010305590729

## NAME AND ADDRESS OF THE APPLICANT

Zhejiang Tengen Electric Co.,Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

## NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Tengen Electric Co.,Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

## NAME AND ADDRESS OF THE FACTORY

Zhejiang Tengen Electric Co.,Ltd. (V024163)  
No.332 Liule Road, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

## PRODUCT NAME, MODEL AND SPECIFICATION

Conventional Change-over Switch

LW28-20; Ui:550V; Uimp:2.5kV; Ith:20A; AC-15:Ue/Ie:AC380V/1.5A; DC-13:Ue/Ie:DC220V/0.14A. See the Appendix for type explanation

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.5-2017

## TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Aug.24,2020

Valid until: Nov.28,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: \_\_\_\_\_

Lu Mei



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China  
<http://www.cqc.com.cn>

C 0376520





# 产品认证证书

附录

第 2 页 共 2 页

证书编号: CQC2013010305590729

纸号: 376520

表 1

操作方式	特征代号	操动器位置													
自复型	A						0° ←	30°							
	B					30° →	0° ←	30°							
定位型	C						0°	60°							
	D					60°	0°	60°							
	E				90°	30°		30°	90°						
	F				120°	60°	0°	60°	120°						
	G				120°	60°	0°	60°	120°	180°					
	H					30°	0°	30°	60°						
	I				60°	30°	0°	30°	60°						
	J				60°	30°	0°	30°	60°	90°					
	K			90°	60°	30°	0°	30°	60°	90°					
	L			90°	60°	30°	0°	30°	60°	90°	120°				
	M		120°	90°	60°	30°	0°	30°	60°	90°	120°				
	N					30°		30°							
	P					90°	0°	90°							
	YH						0°	90°	180°	270°					
	LH							0°	90°	180°	270°				
	TM		30°	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	
			30°	0°	30°	60°	90°	120°	150°	180°	210°	240°			
			30°	0°	30°	60°	90°	120°	150°	180°					
		30°	0°	30°	60°	90°	120°								
		45°	0°	45°	90°	135°	180°	225°	270°						
	22.5°	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°	180°	202.5°	225°	247.5°	270°	

注: 此附录与证书同时使用时有效。

主任: 陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>