

产品认证证书

II型自愿认证

证书编号: CQC20012249858

发证日期: 2020年06月02日
有效期至: 2031年05月20日

委托人名称	浙江天正电气股份有限公司
及注册地址	浙江省乐清市柳市镇苏吕工业区
制造商名称	浙江天正电气股份有限公司
及注册地址	浙江省乐清市柳市镇苏吕工业区
生产企业名称	浙江九策智能电气有限公司
及生产地址	浙江省乐清市柳市镇方斗岩工业区 A2 幢 3-4 层
产品名称和系列、规格、型号	漏电断路器 TGBDLE-80YN, TGBDLE-80Y, TGBDLE-80YH; Uimp:4kV; Ui:690V; Ue:AC400V; In:6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A; 瞬时脱扣类型:C 型、D 型; I _n :30mA/50mA/100mA;可调; 额定剩余动作类:AC 型, 电子式; I _m :2kA; I _{cs} =I _{cn} :4.5kA(TGBDLE-80YN), I _{cs} =I _{cn} :6kA(TGBDLE-80Y), I _{cs} =7.5kA, I _{cn} =10kA(TGBDLE-80YH); 极数:4P(3 个保护极, N 极可开闭); 适用于隔离用;
产品标准和技术要求	GB/T 16917.1-2014, GB/T 16917.22-2008
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人 签发
陈昕 陆楠

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0051276

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC20012249858

Valid from: Jun.02,2020

Valid until:May.20,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT	Zhejiang Tengen Electric Co.,Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	Zhejiang Tengen Electric Co.,Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China
NAME AND LOCATION OF THE FACTORY	Zhejiang Jiuce Intelligent Electric Co.,Ltd. 3-4 Floors of Building A2 in Fangdouyan Industrial Zone, Liushi Town, Yueqing City, Zhejiang Province
PRODUCT NAME, MODEL AND SPECIFICATION	Leakage circuit breakers TGBDLE-80YN, TGBDLE-80Y, TGBDLE-80YH; Uimp:4kV; Ui:690V; Ue:AC400V; In:6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A; Type of Instantaneous Tripping Current : C 、 D ; I _n :30mA/50mA/100mA Adjustable; Rated Residual Operating Type : AC , Electronic Residual Current Tripping Unit; I _{Δn} :2kA; I _{cs} =I _{cn} :4.5kA(TGBDLE-80YN), I _{cs} =I _{cn} :6kA(TGBDLE-80Y), I _{cs} =7.5kA, I _{cn} =10kA(TGBDLE-80YH); Poles :4P(ith three protective poles,Switched N pole); Suitable for isolation;
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 16917.1-2014, GB/T 16917.22-2008
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

陆楠

CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

Tel: +86 10 83886666

C(2) 0051276