

# 产品认证证书

## II型自愿认证

证书编号: CQC2015010307749808

发证日期: 2020年08月24日

有效期至: 2031年05月20日

**委托人名称及注册地址** 浙江天正电气股份有限公司  
浙江省乐清市柳市镇苏吕工业区

**制造商名称及注册地址** 浙江天正电气股份有限公司  
浙江省乐清市柳市镇苏吕工业区

**生产企业名称及生产地址** 浙江天正智能电器有限公司  
浙江省嘉兴市秀洲区中山西路 2777 号

**产品名称和系列、规格、型号** 万能式断路器  
THW3-1600、THW3-1600/4;具体参数详见附件

**产品标准和技术要求** GB/T14048.2-2008

**认证模式** 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 ( www.cnca.gov.cn ) 查验证书信息



授权签字人

签发

陈昕 陆楠



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0056380

# CERTIFICATE OF PRODUCT CERTIFICATION

## TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2015010307749808

Valid from: Aug.24,2020

Valid until: May.20,2031

<b>NAME AND REGISTERED ADDRESS OF THE APPLICANT</b>	Zhejiang Tengen Electrics Co.,Ltd. Sulv Industry Zone,Liushi,Yueqing,Zhejiang,P.R.China
<b>NAME AND REGISTERED ADDRESS OF THE MANUFACTURER</b>	Zhejiang Tengen Electrics Co.,Ltd. Sulv Industry Zone,Liushi,Yueqing,Zhejiang,P.R.China
<b>NAME AND LOCATION OF THE FACTORY</b>	Zhejiang Tengen Smart Electrics Co.,Ltd. No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing, Zhejiang Province, P.R.China
<b>PRODUCT NAME, MODEL AND SPECIFICATION</b>	Air Circuit-breaker THW3-1600、THW3-1600/4;See the Appendix
<b>THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS</b>	GB/T14048.2-2008
<b>TYPE OF CERTIFICATION SCHEMES</b>	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.  
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGN BY

SIGNATURE



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0056380

# 产品认证证书

## II型自愿认证

附 录

证书编号: CQC2015010307749808

第 1 页 共 1 页

纸 号: 56380

THW3-1600、THW3-1600/4

Ue: AC400V/ AC690V; Ui: 1000V

In: 200A、400A、630A、800A、1000A、1250A、1600A

过电流脱扣器类型: 电子式

当Ue=AC400V 时, Icu: 65kA, Ics: 55kA, Icw: 55kA/1s

当Ue=AC690V 时, Icu: 50kA, Ics: 42kA, Icw: 42kA/1s

使用类别: B

极数: 3P、4P

配用的辅助触头 (4N04NC、5N05NC、6N06NC):

AC-15: Ue/Ie: AC400V/0.9A, AC230V/1.5A

DC-13: Ue/Ie: DC220V/0.27A, DC110V/0.55A

符合附录N 的电子附件:

欠压脱扣器: AC230, AC400V

分励脱扣器: AC230, AC400V; DC110V, DC 220V

注: 此附录与证书同时使用时有效。



中国质量认证中心

