

**IEC****IECEE**

Ref. Certif. No.

CN55883

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product

Residual current operated circuit breaker

Name and address of the applicant

Zhejiang Tengen Electric Co.,Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang  
Province, P.R.China

Name and address of the manufacturer

Zhejiang Tengen Electric Co.,Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang  
Province, P.R.China

Name and address of the factory

Zhejiang Tengen Electric Co.,Ltd.  
No.332 Liule Road, Liushi Town, Yueqing City, Zhejiang  
Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

TENGEN

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

TGB1NLE-63Y, TGB1NLA-63Y, TGB1NLG-63Y;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 61009-1:2010(3rd Edition) + AMD 1:2012 + AMD  
2:2013;IEC 61009-2-2:1991(1st Edition)

As shown in the Test Report Ref. No. which forms part of this Certificate

00901- CB2021CQC-100127

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: <http://www.cqc.com.cn>

Date: Jan.13,2022

Signature:

谢肇煦

Xie ZhaoXu


**CB 0066475**

TGB1NLE-63Y, TGB1NLA-63Y, TGB1NLG-63Y;  
Ue: AC220V/230V/240V(2P), AC380V/400V/415V (3P, 3P+N, 4P)  
In: 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;  
instantaneous release type: B type, C type, D type;  
 $I\Delta n$ : 15mA, 30mA, 50mA, 75mA, 100mA, 300mA;  
Type AC (TGB1NLE-63Y), TGB1NLG-63Y (with Overvoltage protection),  
Type A (TGB1NLA-63Y), Residual current release type: Electronic;  
 $I\Delta m$ : 2000A;  $I_{cn}=I_{cs}$ :6000A;  
Number of poles:  
2P (with two protection poles), 3P( with three protection poles), 3P+N (three protection poles, with uninterrupted N pole, not suitable for isolation), 4P (with four protection poles)

Page 1 of 1

Additional information (if necessary)

Date: Jan.13,2022

Signature:   
Xie ZhaoXu