



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE220303007918

Product Moulded Case Circuit Breaker

Applicant Zhejiang Tengen Smart Electrics Co.,Ltd.
No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing,
Zhejiang Province, P.R.China

Type/Model TeM5DC-250HU;

Technical data See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 02401-22119Y29054-1,02401-22119Y29054-2, the submitted sample(s) of the above item complies with:

EN 60947-2:2017/A1:2020;EN 60947-2:2017

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Dec.01,2022

Valid until: Nov.30,2025

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE





CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE220303007918

TeM5DC-250HU;

Ui:1500V;Uimp:12kV;

Ue:DC1500V;

In:63A,80A,100A,125A,140A,160A,180A,200A,225A,250A;

Type of overcurrent release: Thermo-magnetic trip unit, Electro-magnetic trip unit;

Selectivity category:A;

M type:Ics=Icu:20kA($\tau=10\text{ms}$);

H type:Ics=Icu:40kA($\tau=5\text{ms}$);

Wiring mode:3P appearance;

The product is suitable for isolation;

Applicable to PV

(Only the nameplate reflects "IEC 60947-2- Annex P");

Auxiliary:1NO1NC,2NO2NC;lth:3A;

AC-15:Ue/ Ie:AC400V/1.5A;

DC-13:Ue/ Ie:DC220V/0.15A;



CHINA QUALITY CERTIFICATION CENTRE

