



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE200306006736

Product

ATSE

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Solv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model

TGQ1N-250L/3,TGQ1N-250M/3,TGQ1N-250L/4,TGQ1N-250M/4,TGQ1N-320L/3,TGQ1N-320M/3,TGQ1N-320L/4,TGQ1N-320M/4;

Technical data

Uimp:8kV(main circuit),2.5kV(control circuit);Ui:800V(main circuit),400V(control circuit);Ue:AC400V;
Ith:320A;TGQ1N-250L/3,TGQ1N-250M/3,TGQ1N-250L/4,TGQ1N-250M/4:Ie:160A,180A,200A,225A,250A;TGQ1N-320L/3,TGQ1N-320M/3,TGQ1N-320L/4,TGQ1N-320M/4:Ie:250A,280A,300A,315A,320A;Utilization category:AC-33B;Icm:73.5kA(Type L),105kA(Type M);Icn:35kA(Type L),50kA(Type M); Class CB;Method of controlling: ATSE,RTSE; 3P, 4P

This is to certify that, on the basis of the tests undertaken as per Report No. (2019)FQIIDQCE-0186-H1, the submitted sample(s) of the above item complies with:

EN 60947-6-1:2005 + A1:2014

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Mar.09,2023

Valid until: Mar.08,2026

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE

