



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE230304008394

Product Automatic transfer switching equipment

Applicant Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model TGLD-160,TGQKP-160;
Ue:AC400V;Ui:690V;Uimp:8kV;Ith:160A;Ie:100A,125A,14
0A,160A;Utilization
Technical data category:AC-33iB;Icm:17kA;Icw:10kA/30ms;Iq:50kA;ATS
E Class:PC:Transfer Mode:ATSE;Poles: 3P,4P; Controller
Uimp:4kV

This is to certify that, on the basis of the tests undertaken as per Report No.
02402-23119Y29053, the submitted sample(s) of the above item complies with:

EN 60947-6-1:2005 + A1:2014

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only,
and does not include the manufacturing process. Users shall affix the mark in accordance
with the related legislation.

Valid from: Jul.19,2023

Valid until: Jul.18,2026

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE