



# CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Certificate No.: CE210305007372

**Product** AC Contactors

**Applicant** Zhejiang Tengen Electric Co.,Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang  
Province, P.R.China

**Type/Model** TGCA-06M,TGCA-09M,TGCA-12M,TGCA-16M,TGCA-06M...N,TGCA-09M...N,TGCA-12M...N,TGCA-16M...N,TGCA-06M04,TGCA-09M04,TGCA-12M04,TGCA-16M04,TGCA-06M08,TGCA-09M08,TGCA-12M08,TGCA-16M08,TGC1-06M,TGC1-09M,TGC1-12M,TGC1-16M,TGC1-06M...N,TGC1-09M...N,TGC1-12M...N,TGC1-16M...N,TGC1-06M04,TGC1-09M04,TGC1-12M04,TGC1-16M04,TGC1-06M08,TGC1-09M08,TGC1-12M08,TGC1-16M08;

**Technical data** See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2024CQC0305-014958, the submitted sample(s) of the above item complies with:

**EN IEC 60947-4-1:2019**

and fulfills testing requirements of the European Directive:

**2014/35/EU**

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

**Valid from: Aug.05,2024**

**Valid until: Aug.04,2027**

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNATURE:

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE



# CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 2

Certificate No.: CE210305007372

TGCA-06M,TGCA- 09M,TGCA-12M,TGCA-16M,TGCA-06M...N,TGCA-09M...N,  
TGCA-12M...N,TGCA-16M...N,TGCA-06M04,TGCA-09M04,TGCA-12M04,TGCA-16M04,  
TGCA-06M08,TGCA-09M08,TGCA-12M08,TGCA-16M08,TGC1-06M,TGC1-09M,  
TGC1-12M,TGC1-16M,TGC1-06M...N,TGC1-09M...N,TGC1-12M...N,TGC1-16M...N,  
TGC1-06M04,TGC1-09M04,TGC1-12M04,TGC1-16M04,TGC1-06M08,TGC1-09M08,  
TGC1-12M08,TGC1-16M08;

Uimp: 6kV;

Ui: 690V;

Ith: 20A;

Ue: AC220V/230V, AC380V/400V, AC660V/690V;

TGCA-06M,TGC1-06M:

AC-1: Ue/Ie: AC220V/230V/20A, AC380V/400V/20A, AC660V/690V/20A;

AC-3: Ue/Ie: AC220V/230V/6A, AC380V/400V/6A, AC660V/690V/3.8A;

AC-4: Ue/Ie: AC220V/230V/2.6A, AC380V/400V/2.6A, AC660V/690V/1A;

TGCA-09M,TGC1-09M:

AC-1: Ue/Ie: AC220V/230V/20A, AC380V/400V/20A, AC660V/690V/20A;

AC-3: Ue/Ie: AC220V/230V/9A, AC380V/400V/9A, AC660V/690V/4.9A;

AC-4: Ue/Ie: AC220V/230V/3.5A, AC380V/400V/3.5A, AC660V/690V/1.5A;

TGCA-12M,TGC1-12M:

AC-1: Ue/Ie: AC220V/230V/20A, AC380V/400V/20A, AC660V/690V/20A;

AC-3: Ue/Ie: AC220V/230V/12A, AC380V/400V/12A, AC660V/690V/4.9A;

AC-4: Ue/Ie: AC220V/230V/5A, AC380V/400V/5A, AC660V/690V/2A;

TGCA-16M,TGC1-16M:

AC-1: Ue/Ie: AC220V/230V/20A, AC380V/400V/20A, AC660V/690V/20A;

AC-3: Ue/Ie: AC220V/230V/16A, AC380V/400V/16A, AC660V/690V/4.9A;

AC-4: Ue/Ie: AC220V/230V/5A, AC380V/400V/5A, AC660V/690V/2A;

TGCA-06M...N,TGC1-06M...N:



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE



# CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Appendix

Page 2 of 2

Certificate No.: CE210305007372

AC-1: Ue/le: AC220V/230V/20A, AC380V/400V/20A, AC660V/690V/20A;  
AC-4: Ue/le: AC220V/230V/2.6A, AC380V/400V/2.6A, AC660V/690V/1A;  
TGCA-09M...N,TGC1-09M...N:  
AC-1: Ue/le: AC220V/230V/20A, AC380V/400V/20A, AC660V/690V/20A;  
AC-4: Ue/le: AC220V/230V/3.5A, AC380V/400V/3.5A, AC660V/690V/1.5A;  
TGCA-12M...N,TGC1-12M...N:  
AC-1: Ue/le: AC220V/230V/20A, AC380V/400V/20A, AC660V/690V/20A;  
AC-4: Ue/le: AC220V/230V/5A, AC380V/400V/5A, AC660V/690V/2A;  
TGCA-16M...N,TGC1-16M...N:  
AC-1: Ue/le: AC220V/230V/20A, AC380V/400V/20A, AC660V/690V/20A;  
AC-4: Ue/le: AC220V/230V/5A, AC380V/400V/5A, AC660V/690V/2A;  
Us: AC24V,AC36V,AC48V,AC110V,AC220V,AC380V,AC400V,AC415V,50Hz,50/60Hz;  
DC24V,DC48V,DC110V,DC220V;  
3P,4P;  
IP20;  
Auxiliary contacts:  
FD1  
1NO,1NC;  
Ith: 10A;  
AC-15: Ue/le: AC220V/1.6A, AC380V/0.95A;  
DC-13: Ue/le: DC220V/0.15A;



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE