

IEC**IECEE**

®

™

Ref. Certif. No.

CN67193

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Air Circuit-breakers

Name and address of the applicant

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the manufacturer

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the factory

Yueqing Economic Development Branch of Zhejiang Tengen
Electric Co.,Ltd.*Note: When more than one factory, please report on page 2*No.288 Central Avenue, Development Zone, Yueqing City,
Zhejiang Province, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark (if any)

TENGEN

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

TGW3-2000,TGW3-2000H,TGW3-2500,TGW3-2500H;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016/AMD1:2019;IEC 60947-2:2016(5th Edition);IEC 60947-1:2007;IEC 60947-1:2007/AMD1:2010;IEC 60947-1:2007/AMD2:2014

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2024CQC-114682

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Sep.26,2024

Signature:

谢肇旭

Xie ZhaoXu



TGW3-2000,TGW3-2000H,TGW3-2500,TGW3-2500H

Ui:1000V;Uimp:12kV;

Ue: AC380/400/415V,AC660/690V;

TGW3-2000,TGW3-2000H:

In:200A,250A,400A,500A,630A,800A,1000A,1250A,1600A,1900A,2000A;

TGW3-2500,TGW3-2500H:

In: 630A,800A,1000A,1250A,1600A,1900A,2000A,2500A;

Over-current release:Electronic type;

TGW3-2000:

Ue: AC380/400/415V

Icu: 70kA, Ics: 70kA, Icw: 66kA/1s;

Ue: AC660/690V

Icu: 50kA, Ics: 50kA, Icw:50kA/1s;

TGW3-2000H:

Ue: AC380/400/415V

Icu: 80kA, Ics: 80kA, Icw:66kA/1s;

Ue: AC660/690V

Icu: 65kA, Ics: 65kA, Icw:50kA/1s;

TGW3-2500:

Ue: AC380/400/415V

Icu: 80kA, Ics: 80kA, Icw: 66kA/1s;

Ue: AC660/690V

Icu: 65kA, Ics:65kA, Icw:55kA/1s;

TGW3-2500H:

Ue: AC380/400/415V

Icu: 85kA, Ics: 85kA, Icw:85kA/1s;

Ue: AC660/690V

Icu: 65kA, Ics: 65kA, Icw:65kA/1s;

Selectivity category:B; 50/60Hz;

3P,4P; Applicable for isolation;

Auxiliary contacts:

Additional information (if necessary)

Date:

Sep.26,2024

Signature:

谢肇煦

Xie ZhaoXu

IEC

TECEE

®

™

Ref. Certif. No.

CN67193

3NO3NC, 4NO4NC, 5NO5NC, 6NO6NC

Ui:400V;Uimp:2.5kV;lth:16A;

AC-12:Ue/Ie:AC380V/16A;

DC-12:Ue/Ie:DC250V/5A.

Page 2 of 2

Additional information (if necessary)

Date:

Sep.26,2024

Signature:

谢肇煦

Xie ZhaoXu