

Zertifikat *Certificate*

Zertifikatsnummer Certificate No.:

R 50686120 0001

Berichtsnummer Report No.:

CN25OCRA 001

Genehmigungsinhaber License Holder:

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City,
325604 Zhejiang
P.R. China

Fertigungsstätte Manufacturing Site:

Zhejiang Tengen Electric Co., Ltd.
(Yueqing Economic
Development Zone Branch)
No.288 Central Avenue
Development Zone, Yueqing City,
325604 Zhejiang
P.R. China

Prüfzeichen Test Mark:

Geprüft nach Tested according to:

EN IEC 60947-2:2025

Geräteidentifikation
Product Identification
Produkt:
Product:

Moulded case circuit breaker
(Moulded case circuit breaker)

Modell:
Type:

Modelle sind auf nächste(r) Seite(n) gelistet
Type designation(s) are listed on the next page(s)

Technische Daten:
Technical Data:

Technische Daten auf nächste(r) Seite(n) gelistet
Technical Data is listed on the next page(s)

Gültig ab:
Valid from:

2025-07-15

Zertifizierungsstelle:
Certification body:
Ausstellungsdatum:
Date of issue:

2025-07-15

Wencai Zhang



Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
<http://www.tuv.com/safety> E-mail: markcheck@tuv.com

Fax: +49 221 806-3935

Zertifikat *Certificate*

Zertifikatsnummer Certificate No.:

R 50686120 0001

Berichtsnummer Report No.:

CN25OCRA 001

Produkt Product: Moulded case circuit breaker
(Moulded case circuit breaker)

Modell Type:
Bezeichnung Designation:

Code Designation : TGM3E-800xy/abcdefghijklm

(x=L, M, H; y=blank, Z, P; a=3, 3N, 4; b=3; c=00, 08, 10, 20, 21, 23, 30, 40, 41, 43, 50, 51, 52, 54, 70, 71, 18, 28, 38, 47, 45, 48, 68, 66, 78, 77, 75, 55, 56, 58, 59; d=blank, 2; e=B, C; f=blank, III; g=blank, E1, E2, E3, E4, E5; h=blank, C, F, D)

Trademark : (Tengen(Logo))

Number of Poles	: 3P, 3P+N, 4P
Rated Operation Voltage(Ue)	: AC380/400/415V
Rated Frequency	: 50/60Hz
Rated Impulse Withstand Voltage(Uimp)	: 12kV
Rated Insulation Voltage(Ui)	: 1000V
Frame Rated Current(Inm)	: 800A
Breaking Capacity Level	: L, M, H
Rated Current of Electronic Release(In)	: 800A(Ir:315~800A adjustable) 630A(Ir:250~630A adjustable)
Rated Instantaneous Short-circuit Current Setting:(Ii):	blank, E1, E2, E3, E4, E5:(3~14)Ir(adjustable)
Rated Ultimate Short-circuit Breaking Capacity(Icu):	50kA(y=L); 70kA(y=M); 100kA(y=H)
Rated Service Short-circuit Breaking Capacity(Ics):	50kA(y=L); 70kA(y=M); 75kA(y=H)
Rated Short-circuit Withstand Current(Icw)	: 10kA/1s
Rated Duty	: Uninterrupted duty
Suitability for Using in IT System	: No
Suitability for Isolation	: Yes
Method of Installation	: Fixed, Plug-in, Withdrawable

Auxiliary and Control Circuit Parameters:

Shunt Release(MX3M40)(Us): AC220/230/240V; AC380/400/415V; 50/60Hz;
DC24V; DC110V; DC220V; Ui:690V; Uimp:4kV

Undervoltage Release(MN3M40)(Us): AC220/230/240V; AC380/400/415V;
50/60Hz; Ui:800V; Uimp:4kV

Motor operating mechanism(CD3M80-3P, CD3M80-4P)(Us):

AC/DC110/220/230/240V; AC380/400/415V, 50/60Hz;

DC24V; Ui:690V; Uimp:4kV

Auxiliary Switch(OF3M40) or Alarm Contact Circuits(SD3M40):

1N01NC; 2N02NC; Ui:690V; Uimp:4kV; Ith=5A; 50/60Hz;

AC-15: AC380/400/415V/0.3A; DC-13: DC110/220/250V/0.15A

ANLAGE (Appendix): 1

